

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7320-0328:161 Page 1 of 1

CATEGORY: Speakers

LISTEE: Potter, 2081 Craig Road, St. Louis MO 63146
Contact: Brad Serangeli (314) 878-4321

DESIGN: Models SS25-2R, RS25-2W, RS70-2R, RS70-2W speaker/strobe; Models SS25-153075R2, RSS25-153075W2, SSS70-153075R2, RSS70-153075W2 combination speaker/strobes. Units are comprised of a steel or aluminum die-cast baffle mounted to a speaker basket, printed wiring board, transformer and components with field wiring. The speaker can be installed in a standard 4" electrical box. Refer to listee's data sheet for detailed product description and operational considerations.

RATING: 25 and 70 Vrms
1/4, 1/2, 1, 2, Wattage Taps
SSS25-153075R2, RSS25-153075W2, and
SSS70-153075R2, RSS70-153075W2: 15/75 or 30/120 cd

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as speaker or speaker/strobes for use with separately listed compatible fire alarm control units.

If this appliance is required to produce a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1996 Edition, the appliance must be used with a fire alarm control unit that can generate the temporal pattern signal. Refer to manufacturer's Installation Manual for details.

XLf: 7320-0587:113

03-13-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 20, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager